




No. F6/DFS/MS/School/WZ/2024/ 478

Dated:- 29/05/2024

FIRE SAFETY CERTIFICATE

Certified that the New Saraswati Public Secondary School Located at Ext. No. 2, Nangloi, Delhi-110041, comprised of 02 Blocks – 1st block (Ground + 02 Upper Floors) & 2nd block (Ground + 01 Upper Floor) only owned/occupied by the New Saraswati Public School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2021/WZ/383 dated 27/05/2021. The said premises was re-inspected by the officer concerned of this department on 17/05/2024 in the presence of Sh. Lalit Kumar Yadav (Owner) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 29/05/2024 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 29/05/2024 at New Delhi by.


(Atul Garg)
Director
Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, New Saraswati Public School, Ext. No. 2, Nangloi, Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.